

(SEE PLOT PLAN)

58

56

* OUTFALL MUST
BE 75' MIN
FROM FIELD

DRAINAGE
BROOK
EASEMENT

APPROX 12

REVIEWED AND APPROVED ^{CS}
IN ACCORDANCE WITH ^{10/4/84}
REQUIREMENTS OF THE
TOWN OF RYE, NEW HAMPSHIRE

[Signature]
[Signature]
[Signature] SELECTMEN
DATE 10/4/84

PERC TEST

DATE: 9/20/84

DEPTH OF HOLE: 30"

RATE OF PERC: 6 MIN/IN

DESIGN LOADING: 3 BEDROOMS

AREA REQUIRED: 675 SQ. FT.

PROPOSED SYSTEM: 25 x 30 FOR
750 SQ. FT. AREA PROVIDED

OK'D 4 BEDROOM
REVISION BY
SEE PLAN
NO REVISION

PLAN OF PROPOSED SEPTIC SYSTEM

LOCUS: LOT 55-14 FERN AVENUE
RYE, N.H.

APPLICANT

OWNER: ROBERT V. & DIANNE HIGGINS
120 FERN AVE
RYE, NH. 03870

REVIEWED AND APPROVED
IN ACCORDANCE WITH THE
REQUIREMENTS OF THE
NEW HAMPSHIRE
WATER SUPPLY & POLLUTION
CONTROL COMMISSION

APPLICANT: ANNE W. BIALOBRZESKI
247 LANDING ROAD
HAMPTON, N.H. 03842
DESIGNER PERMIT #348

Signed *[Signature]*
Date 10-11-84

NEW HAMPSHIRE
Designer
of
Subsurface Disposal
Systems

Ann W. Bialobrzski
No. 348
Water Supply & Pollution Control

DATE: 10/1/84

APPROVAL: _____

17A
SEE REVISION

(SEE PLOT PLAN)

53.4 SAND & GRAVEL 8'

PERC TEST

DATE: 9/20/84

DEPTH OF HOLE: 30"

RATE OF PERC: 6 MIN/IN

DESIGN LOADING: 4 BEDROOMS

AREA REQUIRED: 900 SQ. FT.

PROPOSED SYSTEM: 25 x 40 FOR 1,000 SQ. FT. AREA PROVIDED

REVISED PLAN OF PROPOSED SEPTIC SYSTEM

LOCUS: LOT 55-14 FERN AVENUE
RYE, N.H.

SEE APPROVAL #115829

OWNER: ROBERT V. & DIANNE HIGGINS
120 FERN AVE
RYE, NH. 03870

APPLICANT

APPLICANT: ANNE W. BIALOBRZESKI
247 LANDING ROAD
HAMPTON, N.H. 03842
DESIGNER PERMIT #348

DATE: 10/24/84

APPROVAL:

17

REVIEWED AND APPROVED
IN ACCORDANCE WITH
REQUIREMENTS OF THE
TOWN OF RYE, NEW HAMPSHIRE

contingency
10/19/84

M. L. Chung
J. B. Higgins

SELECTMEN

DATE

REVIEWED AND APPROVED
IN ACCORDANCE WITH THE
REQUIREMENTS OF THE
NEW HAMPSHIRE
WATER SUPPLY & POLLUTION
CONTROL COMMISSION

Signed

Date

10/30/84

C.A. 115829

